



(Slab not shown for clarity)

NOTES:

1. Refer to the Element Prescriptive Engineering for reinforcement design of Element ICF walls.
2. On bearing surfaces less than 8" (nom.), joists must be staggered by a min. of 6".
3. No fasteners required in open holes when joist bears on concrete. Unless noted otherwise (typ.).
4. When calculating bearing elevation - add $\frac{1}{4}$ " to the thickness of the slab to allow for the joist bearing shoe.



©Copyright Logix Brands Ltd. (2024) All rights reserved. No part of the work contained herein as covered by this copyright may be reproduced or used in any form, or any means - graphic, electronic or mechanical, including without limitation photocopying.

By using these drawings, you agree to assume all risks associated therewith. See Logixbrands.com/Disclaimer-Drawings for a full copy of disclaimer.

Drawing:
5.7.3.1

Date:
Mar 03/23

Pg:
1/1

Title:
HAMBRO JOISTS BUTTED AGAINST
ELEMENT